

Title 33

ENVIRONMENTAL QUALITY

Part XI. Underground Storage Tanks

Chapter 1. Program Applicability and Definitions

§101. Applicability

A. – C.2.a.v. ...

b. LAC 33:XI.701-705 does not apply to any UST system that stores fuel solely for use by emergency power generators UST systems installed prior to August 20, 2009. Emergency power generator UST systems installed or replaced on or after August 20, 2009, are subject to all requirements of LAC 33:XI, including the interstitial monitoring release detection requirements of LAC 33:XI.701-705.

AUTHORITY NOTE: Promulgated in accordance with R.S. 30:2001 et seq.

HISTORICAL NOTE: Promulgated by the Department of Environmental Quality, Office of Solid and Hazardous Waste, Underground Storage Tank Division, LR 16:614 (July 1990), amended LR 17:658 (July 1991), LR 18:727 (July 1992), amended by the Office of Environmental Assessment, Environmental Planning Division, LR 29:1467 (August 2003), amended by the Office of the Secretary, Legal Affairs Division, LR 35:**.

Chapter 3. Registration Requirements, Standards, and Fee Schedule

§303. Standards for UST Systems

A. – D.2.f. ...

i. any of the accepted piping designs listed in Subparagraphs D.2.a-e of this Section shall be fabricated with double-walled or jacketed construction in accordance with Subsection A of this Section, shall be capable of containing a release from the inner wall of the piping, and shall be designed with release detection in accordance with LAC 33:XI.701.B.4; or

ii. ...

g. if 25 percent or more of the piping to any one UST is replaced after December 20, 2008, it shall comply with Clause D.2.f.i or ii of this Section. If a new motor fuel dispenser is installed at an existing UST facility and new piping is added to the UST system to connect the new dispenser to the existing system, then the new piping shall comply with Clause D.2.f.i or ii of this Section. Suction piping that meets the requirements of LAC 33:XI.703.~~D-B~~.2.b.i-v and suction piping that manifolds two or more tanks together are not required to meet the secondary containment requirements outlined in this Paragraph.

D.3. – E.6.b. ...

AUTHORITY NOTE: Promulgated in accordance with R.S. 30:2001 et seq.

HISTORICAL NOTE: Promulgated by the Department of Environmental Quality, Office of Solid and Hazardous Waste, Underground Storage Tank Division, LR 11:1139 (December 1985), amended LR 16:614 (July 1990), LR 17:658 (July 1991), LR 18:728 (July 1992), amended by the Office of Environmental Assessment, Environmental Planning Division, LR 26:2558 (November 2000), LR 28:475 (March 2002), amended by the Office of Environmental Assessment, LR 31:1066 (May 2005), amended by the Office of the Secretary, Legal Affairs Division, LR 31:2520 (October 2005), LR 33:2171 (October 2007), LR 34:2116 (October 2008), LR 35:**.